TEST CERTIFICATE

according to the results of the examination of the slide-blocking property in wet loaded barefoot areas of floor coverings

Tested material: Elastic floor covering of soft-polyvinyl chlorid (PVC)

Signification: ALKORPLAN 2000

anti slip swimming pool sealing

Type-No.:

81116

Basic size:

Rolled goods (25.000 x 1.650 x 1,5 mm)

(test material 1000 x 500 x 0,75 mm)

Colour-No.:

52341 (adria blue)

Surface:

Unprofiled, nep structure (d = 3,5 mm;

centre to centre distance 5/6 mm),

Testing object:

Delivery of the test material has been effected in a ready-to-test

condition.

Producer / Supplier:

RENOLIT IBERICA SA

Carretera del Montnegre sin 08470 Sant Celoni (Barcelona)

SPAIN

Customer:

RENOLIT IBERICA SA

Carretera del Montnegre sin 08470 Sant Celoni (Barcelona)

SPAIN

Test ordering:

14 February 2008

Certificate number:

99480802.001

Sampling:

Sent by the customer to the research institute

Standard of determination:

DIN 51097, ed. 11/92

"Testing of floor coverings; determination of the anti-slip properties; wet-loaded barefoot areas;

walking method - ramp test"

Side-blocking Floorings – List NB

"Requirements of the control-committee"

Result:

Average inclination angle 27°

Conclusion:

Requirements on the slide-blocking property for

the range of application C are fulfilled.



SÄUREFLIESNER-VEREINIGUNG E. V. RESEARCH AND ADVISORY INSTITUTE FOR WALL AND FLOOR COVERINGS Managing Director

Dr.-Ing. E. H. Nolting

Großburgwedel, 9. April 2008 Schu/Pp

The result is related to the tested material.

The report is given for 5 years (beginning data of delivery report).

Publication and reproduction of this report is only allowed in unabridged form.

